

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1273:106 Page 1 of 1

CATEGORY: Control Unit (Non High Rise)

LISTEE: Digital Security Control, 95 Bridgeland Avenue, Toronto, Ontario, Canada M6A 1Y7*
Contact: Dan Nita (905) 760-3000 Fax (905) 760-3020

DESIGN: Models PC4010CF, PC4020CF, P-864CF and PC16128CF fire alarm control units.
Power-limited, local, central station and remote station (Protected Premise), automatic, manual, noncoded, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PC4010CF, PC4020CF	Controller Module
PC4700, PC4701, P4700, P4701	Commercial Fire Module
PC4001CFB, P4001CFB	Enclosure
PC4108, P4108, PC4116, P4116	Zone Expander
LCD4520, LCD4521, P4521	Keypads
PC4702BP, P4702BP	Fire Bell Module
PC4612, P4612, PC4632, P4632	Annunciator Modules
PC4664, P4664	Annunciator Modules
PC4204CF, P4204CF	Power Supply/Relay Module
PC4216, P4216	Output Module
LCD-4520T, LCD-4521/PRS400F	Keypads
LCD-4521T/PRS400FT	Keypads
PC4612A, P4612A	Zone Annunciator
PAMP-702, AMP-702	Addressable Point Module

RATING: 120 VAC, 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name (DSC) or "partner", model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to listee's Installation Instruction Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager